

Requests for Proposals for Security Cameras

Questions and Answers

Is there a link to obtain the bid documents? No

Are there drawings available for the project? No

What is the height & width of the parking structure?

The footprint of the building is 230' x 121'. The roof deck height is 99' from street level and the elevator machine room/stair tower roof deck height is 123' from street level.

There will be ten (10) cameras. One viewing cars coming into the garage, one (each) in two parking booths, one over the elevator (Pine Street), two in the management office, one showing the event sellers lane, one over the elevator (Olive Street), and two on the roof.

1. Camera and DVR must be HD quality recording.
2. Provide and install a secured server rack to hold DVR and equipment related to camera system.
3. Cameras must be connected to a dedicated camera switch that connects to the DVR.
4. DVR must have dual NIC cards to connect to dedicated camera switch and internet. Internet connection must have ability to throttle bandwidth going out to internet.
5. Solution must be viewable by multiple people using client application locally, web browser and mobile app via internet.
6. Include a 55" TV & wall mount.